



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7165-1157:0135
<b>CATEGORY:</b>	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)
<b>LISTEE:</b>	Digital Monitoring Products, Inc. 2500 N. Partnership Blvd, Springfield, MO, 65803 Contact: Wilson, James 417-447-9697 Email: jwilson@dmp.com
<b>DESIGN:</b>	<p>Models XR150, XR350, and XR550 combination fire and burglary alarm control units. Local, remote station, proprietary and central station services. Models may have a combination of the following suffixes: D (dialer), N (network), E (encryption) or FC (fire control). Refer to listee's data sheet for additional detailed product description and operational considerations. System components:</p> <p>XR150, XR350, XR550: Main Board</p> <p>341, 349, 350, 350A, 352P 352X: Enclosures</p> <p>352S: Battery Enclosure</p> <p>630F: Supervised LCD Keypad</p> <p>7070, 7070A, 7073, 7073A, 7170, 7170A, 7173, 7173A, 7570, 7570A, 7573, 7573A: LCD Keypads</p> <p>325: Transformer Bracket</p> <p>322, 323, 324, 324P, 327: Transformers</p> <p>711, 714, 714-8, 714-16, 715, 715-8, 715-16: Zone Expanders</p> <p>711S: Zone Expander (NOT for use with XR350)</p> <p>716: Output Expander</p> <p>717: Annunciator Module</p> <p>860: Relay Module</p> <p>893A: Dual Phone Line Module</p> <p>734, 734N: Wiegand Interface</p> <p>710: Bus Splitter</p> <p>270: Network Transient Suppression Module</p> <p>277: Trouble Sounder</p> <p>9060, 9063: Wireless Keypads</p> <p>263C, 263H: Cellular Communicator (May be used as the standalone primary</p>



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

	<p>communicator)</p> <p>263LTE, 263LTE-FN: Cellular Communicator (NOT for use with XR350) (May be used as the standalone primary communicator)</p> <p>865, 866, 867: Indicating Module</p> <p>869: Initiating Module</p> <p>303: Reset/Silence Switch</p> <p>1100X, 1100XH: RF Wireless Receiver</p> <p>1100R: Wireless Repeater</p> <p>1103: Wireless Transmitter</p> <p>1135: Wireless Siren</p> <p>*271: Ground Fault Detector Module</p>
<b>RATING:</b>	120 VAC, 0.5 A, 60 Hz
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.
<b>APPROVAL:</b>	Listed as combination fire and burglary alarm control units for use with separately listed electrically compatible initiating and indicating devices. Refer to listee's Installation Instructions Manual for details.
<b>NOTES:</b>	<p>1. The Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.</p> <p>2. Burglary and other non-fire functions were not examined.</p>

5-20-24 MH

\*Revised





**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/10/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division