



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7167-1157:0501
CATEGORY:	7167 - CONTROL UNIT (HOUSEHOLD)
LISTEE:	Digital Monitoring Products, Inc. 2500 N. Partnership Blvd, Springfield, MO, 65803 Contact: Wilson, James 417-447-9697 Email: jwilson@dmp.com
DESIGN:	<p>Digital Monitoring Products Models XTL Touch, combination household fire and burglary wireless control unit. Model XTL Touch has WiFi Communication. Inherent power limited. The built-in receiver for wireless sensors and detectors supports up to 99 wireless devices. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:</p> <p>XTL Touch Control Panel</p> <p>265H, 265LTE Cellular Communicators</p> <p>1164 Wireless Smoke Detector</p> <p>1164NS Wireless Smoke Detector</p> <p>1100R Wireless Repeater</p> <p>1184 Wireless Carbon Monoxide detector</p> <p>1183 Wireless Heat Detector</p> <p>9060, 9063, 9862, 9863 Wireless Keypads</p> <p>1135 Wireless Siren</p> <p>1103 Wireless Transmitter</p>
RATING:	<p>Primary Input Power: 100-240VAC, 60hz, .2A plug in power supply</p> <p>Output Power: 12 VDC, 0.5 A</p> <p>Secondary Power: Standby battery, 3.7 VDC</p>
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating and ETL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:	Listed as combination household fire and burglary alarm control unit for use with separately listed compatible initiating and indicating devices.
NOTES:	<ol style="list-style-type: none">1. The Fire Alarm Verification Feature (delay of fire alarm signal), not approved for use in California.2. Burglary and other non-fire functions were not examined.

09-07-2018 dcc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division