

TMSentry

Quick Programming Sheet

Name _____ Account Number _____ Date _____

Address _____ City _____ State _____ Zip _____

When any panel programming is changed, the STOP routine must run and “Saving Program” must display on the keypad in order to save the programming changes. Refer to the TMSentry Installation and Programming Guide (LT-2862).

Factory default values are shown in **bold** type.

Communication

Account Number _ _ _ _ _ (1 to 65535, default = **12345**)

The Communication charts below contain all available options for communication programming. Refer to the Available With row to determine which option is available for the communication type being programmed.

Comm Type	Checkin Mins	Fail Time	Encrypt	Receiver IP	Receiver Port
NONE NET CELL	2-240 (200) MIN CELL 3-240 MIN	2- 240 MIN CELL 3-240 MIN	NO YES		Default 2001
	NET CELL	NET CELL	NET CELL	NET CELL	NET CELL

Network Options

DHCP **NO** **YES**
Local IP Address _ _ _ . _ _ _ . _ _ _ . _ _ _
Gateway Address _ _ _ . _ _ _ . _ _ _ . _ _ _
Subnet Mask _ _ _ . _ _ _ . _ _ _ . _ _ _
DNS Server _ _ _ . _ _ _ . _ _ _ . _ _ _
Passphrase _ _ _ _ _

Area Information

Auto Arm **NO** YES
Auto Disarm **NO** YES

Zone Information

Zones		Type	Area
Assign Disarm condition for NT, DY, EX, A1, and A2 only.		--	
Assign Prewarn and Entry Delay for EX only.		NT	
Assign Retard and Presignal for FI, SV, A1, A2, and PN only.		DY	
		EX	
		FI	
		PN	
		EM	1
		SV	to
		A1	6
		A2	
		FV	
		AR	
		CO	
		DB	
Zone Type Defaults			
NIGHT		NT	
DAY		DY	
EXIT		EX	
FIRE		FI	
PANIC		PN	
EMERGENCY		EM	
SUPERVISORY		SV	
AUXILIARY 1		A1	
AUXILIARY 2		A2	
FIRE VERIFY		FV	
ARMING		AR	
CARBON MONOXIDE		CO	
INSTANT		IN	
DOORBELL		DB	
#	Zone Name		