

Version 101 Update

Updated Version 101 (7/31/24) firmware is now available for 7830F-R Graphic Remote Annunciators.

Improvements

Updated Version 101 (7/31/24) supports the XF6 Version 241 (8/5/24) Inspection Reminder Update.

To remain in compliance, Fire Alarm Control Panels require an inspection every 3 months, every 6 months, or once a year. Previously, the inspection scheduling was organized by the installing or servicing company.

Now, XF6 Series panels include inspection reminders for fire systems. This allows for the panel to remind the Dealer, Monitoring Center, and End User that an inspection needs to be performed to remain in compliance.

When an inspection is due, the keypad annunciates and displays a message reminding the user that their inspection is due soon. The End User can acknowledge the reminder to silence and clear the message.

A technician can enter into the keypad menu and select that they have completed the inspection. This will reset the inspection reminder countdown.

Obtaining the New Firmware

7830F-R Graphic Remote Annunciator firmware updates are available, free of charge, from DMP's [Product Software Downloads](#) page.